



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING & INVESTIGATIONS DIVISION  
BUILDING MATERIALS LISTING PROGRAM**

**LISTING SERVICE**

<b>LISTING No.:</b>	3774-2373:0001
<b>CATEGORY:</b>	3774 - ELECTRIC LOCKS
<b>LISTEE:</b>	Alarm Controls Corp. 10027 S 51st St., Suite 102, Phoenix, AZ, 85044 Contact: Peabody, Josh 6235824626 Email: josh.peabody@assaabloy.com
<b>DESIGN:</b>	<p>Models 1200DE-CA15S and 1200DE-CA30S Special Locking Arrangement Delayed Egress Electromagnetic Door Lock. Products are intended to be mounted to the fire door frame header and operate by direct force on swinging fire doors. The lock consists of an electromagnet mounted to the door frame and an armature plate mounted to the fire door. The included visual display countdown timer employs a voice and alarm tone with several language options or only alarm tone. Intended for indoor use only.</p> <p>Refer to listee's data sheet for additional detailed product description and operational considerations.</p>
<b>RATING:</b>	12/24 VDC
<b>INSTALLATION:</b>	In accordance with listee's printed installation instructions, NFPA 101, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.
<b>MARKING:</b>	Listee's name, model number, rating, and UL label.
<b>APPROVAL:</b>	Listed as delayed egress electromagnetic door lock for use with outward swinging type fire doors rated up to 3 hours with a maximum opening size of 48" width x 96" height, when installed in accordance with the California Building Code. Authority having jurisdiction shall be consulted prior to installation. Refer to listee's Installation Instruction Manual for details. Models complies with the applicable requirements in UL 10C, 3rd Edition and UL 294, 7th Edition.
<b>NOTES:</b>	

5-18-23 VWW



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING & INVESTIGATIONS DIVISION  
BUILDING MATERIALS LISTING PROGRAM**

**LISTING SERVICE**



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

**Date Issued: 07/03/2023**

**Listing Expires: 06/30/2024**

Authorized By: **Victor Wong**, Program Coordinator  
Fire Engineering & Investigations Division